JOURNAL OF ADVANCED ELECTRICAL AND ELECTRONIC ENGINEERING

Vol 2 Issue 3 (2026)

http://jaeee.org/

Machine Learning Approaches for Predictive Maintenance of Electrical Equipment

Professor Nagi Gebraeel

H. Milton Stewart School of Industrial and Systems Engineering, Georgia Institute of Technology, Atlanta, Georgia, United States.

Abstract

Electrical equipment is essential to industrial production, energy distribution, transportation, and infrastructure services. Unexpected failures of motors, transformers, generators, and other electrical assets can result in operational disruptions, repair costs, and safety risks. Predictive maintenance offers an alternative to maintenance based solely on fixed schedules by using equipment condition data to identify developing problems and support timely intervention. Machine learning can analyze measurements such as vibration, temperature, current, voltage, and acoustic signals to detect anomalies, classify faults, and estimate remaining useful life. This review discusses the principal machine learning approaches used in predictive maintenance, including supervised learning, unsupervised learning, and deep learning. It examines data collection, signal processing, model evaluation, and practical deployment for electrical equipment. Particular attention is given to limited fault data, changing operating conditions, model interpretability, and the distinction between identifying a current fault and forecasting a future failure. The review concludes that machine learning can strengthen maintenance decisions when models are evaluated on representative equipment data and combined with engineering knowledge, appropriate safeguards, and human oversight.

Keywords

Predictive maintenance, machine learning, electrical equipment, fault diagnosis, remaining useful life

INTRODUCTION

Electrical equipment plays a central role in power generation, manufacturing, transportation, and commercial infrastructure. Equipment such as electric motors, transformers, generators, circuit breakers, and power converters is often required to operate continuously under varying loads and environmental conditions. Over time, mechanical wear, insulation deterioration, overheating, and other stresses can reduce reliability. Maintenance has traditionally followed either a corrective or

a preventive approach. Corrective maintenance takes place after a failure, while preventive maintenance is performed at predetermined intervals. Although scheduled inspections are valuable, they may not always reflect the actual condition of an individual asset. Equipment may deteriorate sooner than expected, or components may be replaced while they still have useful life. Predictive maintenance uses information about equipment condition to support decisions about when inspection or repair may be needed. Machine learning contributes by identifying relationships in historical and real-time data that may be difficult to describe with fixed rules. Depending on the available data and objective, a model may detect unusual behavior, classify a fault, estimate failure risk, or forecast remaining useful life. These tasks are related but require different evidence and evaluation methods [1–3]. This article presents a narrative review of machine learning approaches for predictive maintenance of electrical equipment. It discusses key methods and their practical limitations, with particular attention to the connection between model outputs and maintenance decisions.

Predictive Maintenance and Equipment Reliability:

Predictive maintenance aims to identify signs of equipment deterioration early enough for an organization to plan an appropriate response. It commonly combines condition monitoring, data analysis, equipment history, and maintenance planning. Measurements are interpreted alongside operating conditions and engineering knowledge to determine whether an asset requires further inspection. The approach differs from fixed-interval maintenance because decisions can reflect the observed condition of a particular asset. For example, two motors with the same installation date may experience different loads, temperatures, and operating hours. As a result, their maintenance needs may differ. The usefulness of a predictive maintenance system depends on more than the choice of algorithm. Sensors must capture meaningful signals, maintenance records must describe relevant events, and predicted problems must be presented early enough for action. An alert that arrives only moments before failure may have limited planning value, even if it is technically correct. Reviews of maintenance in the power industry emphasize that condition monitoring must be integrated into a broader maintenance strategy [4].

Common Failure Modes in Electrical Equipment:

Electrical equipment can experience both electrical and mechanical faults. In motors, frequently monitored problems include bearing deterioration, rotor defects, winding faults, shaft misalignment, and cooling problems. These conditions may appear in vibration, current, temperature, or acoustic measurements, although their signatures can overlap [5, 6]. Transformers require attention to insulation condition, temperature, moisture, and other indicators of degradation. Depending on the equipment and monitoring system, relevant measurements may include dissolved gas analysis, partial discharge activity, and thermal data. Circuit breakers and switchgear can experience problems associated with contact wear, insulation deterioration, or operating mechanisms. Understanding failure mechanisms helps determine what data to collect and how to interpret model outputs. A change in vibration, for instance, may indicate a bearing issue, but it may also result from a change in load or a loose sensor. Therefore, a model's output should be considered together with operating context and inspection evidence.

Data Collection and Condition Monitoring:

Predictive maintenance begins with the collection of reliable data. Vibration sensors can capture mechanical behavior in rotating equipment, while current and voltage measurements provide information about electrical performance. Temperature sensors and thermal cameras may reveal abnormal heating. Acoustic sensors can capture sound associated with mechanical or electrical activity, and equipment controllers can provide operating hours, load, speed, and alarm records.

For rotating machines, vibration and motor current signature analysis are widely studied monitoring approaches. Combining multiple data sources can improve the information available for diagnosis, but it also introduces challenges involving sensor synchronization, storage, and interpretation [5–7]. Maintenance logs are equally important. They can provide information about inspections, repairs, component replacements, and confirmed faults. However, records may be incomplete or inconsistent. Before model development, organizations should define what constitutes a fault, record when it was confirmed, and distinguish the first visible symptoms from the date of repair.

Data Preparation and Feature Extraction:

Raw equipment data usually require preparation before they can be used for machine learning. Common steps include checking sensor quality, aligning timestamps, handling missing values, removing duplicate records, and dividing continuous signals into meaningful time windows. Data should also be associated with relevant operating conditions, such as speed, load, and ambient temperature. Feature extraction converts raw signals into measurements that describe their behavior. For vibration signals, examples include root mean square amplitude, peak values, and frequency components. Current measurements may be analyzed for spectral patterns associated with electrical or mechanical problems. Temperature trends, rates of change, and differences between components can also be useful. Feature selection should be guided by engineering knowledge as well as statistical analysis. A feature that appears strongly related to a fault in one dataset may instead reflect a particular operating condition or a recording artifact. It is also important to prevent data leakage: information from the future or from the test set must not influence model training. For example, overlapping windows from the same equipment run should not be split carelessly between training and testing.

Supervised Machine Learning Approaches:

Supervised learning uses examples with known labels or outcomes. For fault classification, a dataset might contain measurements labeled as normal operation, bearing fault, or winding fault. Common algorithms include decision trees, random forests, support vector machines, and artificial neural networks. Decision trees provide understandable decision rules, while random forests combine many trees to model more complex relationships. Support vector machines can be useful when appropriate features are available and the dataset is relatively small. Neural networks can learn nonlinear relationships, though their performance depends on the quantity and quality of training data. The main limitation of supervised learning is its dependence on representative labeled examples. Serious equipment failures may be rare, and labels recorded in maintenance systems may not precisely match the time when a fault began. A classifier trained on one motor or operating environment may also perform poorly on another. Therefore, reported accuracy should be interpreted alongside the data collection and testing procedures [3, 8].

Unsupervised Learning and Anomaly Detection:

Unsupervised learning can be useful when examples of confirmed failures are limited. Instead of learning from many labeled fault classes, an anomaly detection system learns patterns associated with normal operation and flags observations that differ from them. Methods include clustering, isolation forests, and autoencoders. An autoencoder, for example, can be trained to reconstruct normal measurements. A large reconstruction error may suggest that new data differ from the patterns encountered during training. However, an anomaly does not automatically indicate a developing fault. A new operating mode, a sensor fault, or a temporary change in load can also trigger an alert. Anomaly detection is therefore best treated as an inspection aid. Thresholds should be selected using representative operating data, and alerts should be reviewed against maintenance records and engineering observations. Monitoring performance over time is necessary because normal behavior can change as equipment ages or operating practices evolve.

Deep Learning and Time-Series Analysis:


Deep learning methods can learn patterns directly from complex signals or from representations such as frequency spectra. Convolutional neural networks are widely studied for fault diagnosis because they can identify local patterns in vibration signals or other measurements. Recurrent neural networks and long short-term memory networks can model sequences, making them relevant to trends that develop over time [8, 9]. For example, a deep learning system may process successive vibration windows to identify changes associated with bearing degradation. Alternatively, a model may analyze temperature, load, and current together to estimate whether equipment behavior is becoming unusual. Deep learning is not automatically the best choice for every application. Complex models may require substantial data, computational resources, and careful tuning. A simpler model based on well-understood features may be easier to deploy and maintain when data are limited. Comparisons should use the same test conditions and should include practical concerns such as inference time, sensor availability, and explainability.

Remaining Useful Life Estimation and Maintenance Planning:

Remaining useful life, or RUL, is the estimated time until an asset reaches a defined end-of-life condition. Unlike fault diagnosis, which identifies a current or existing condition, RUL estimation attempts to forecast how much useful operating time remains. The end-of-life condition must be defined clearly, such as a functional failure or a specified maintenance threshold. RUL models can use degradation trends, historical failure data, or a combination of data-driven and engineering models. Their estimates are uncertain because future loading, operating conditions, and failure mechanisms may not be known. For that reason, an interval or range can be more informative than a single predicted date. Model performance can be evaluated using measures such as mean absolute error and root mean square error, but these should be supplemented by measures that consider timing and uncertainty. An estimate that is too late may create a different operational risk from one that is too early. NASA's prognostics repository provides datasets, including bearing experiments, that can support research; however, results from a public dataset should not be assumed to transfer directly to a particular industrial site [10, 11].

Model Evaluation, Deployment, and Future Directions:

A predictive maintenance model should be tested on data that reflect its intended use. Where possible, evaluation should separate equipment units, operating periods, or sites so that the test data represent conditions the model has not already seen. Randomly dividing highly similar signal windows can produce an overly optimistic estimate of performance. For fault detection, useful measures include precision, recall, false-alarm frequency, and the time between an alert and a confirmed fault. Overall accuracy alone can be misleading when failures are rare. For RUL estimation, evaluation should consider prediction error, uncertainty, and whether the forecast provides enough time to plan maintenance [11]. Deployment also requires a process for responding to alerts. Maintenance personnel need information about the affected asset, the reason for the alert, and the recommended next inspection step. Models should be monitored for changes in data quality and performance, especially after equipment replacement, sensor changes, or shifts in operating conditions. Future work includes combining physical models with machine learning, improving the transfer of models between equipment, and developing methods that use fewer labeled failures. Explainable models and uncertainty estimates can also help engineers assess whether a prediction is credible. The most useful systems will connect model outputs to practical maintenance decisions rather than treating prediction accuracy as the only objective [2, 12].



Summary

Machine learning offers a range of tools for monitoring electrical equipment and supporting predictive maintenance. Supervised models can classify known faults when reliable labels are available, while anomaly detection can identify unusual behavior when failure examples are scarce. Deep learning can analyze complex signals and time series, and prognostic models can estimate remaining useful life where appropriate data and failure definitions exist.

Successful implementation depends on reliable sensors, meaningful maintenance records, careful testing, and engineering interpretation. A model should be assessed under realistic operating conditions and monitored after deployment. Machine learning is most valuable when its predictions provide sufficient time and evidence for maintenance teams to make informed decisions.

References

Carvalho, T. P., Soares, F. A. A. M. N., Vita, R., Francisco, R. da P., Basto, J. P., & Alcalá, S. G. S. (2019). A systematic literature review of machine learning methods applied to predictive maintenance. *Computers & Industrial Engineering*. https://doi.org/10.1016/j.cie.2019.106024

Application-wise review of machine learning-based predictive maintenance: Trends, challenges, and future directions. (2025). *Applied Sciences*. https://www.mdpi.com/2076-3417/15/9/4898

Data-driven fault diagnosis for electric drives: A review. (2021). *Sensors*. https://doi.org/10.3390/s21124024

From corrective to predictive maintenance—a review of maintenance approaches for the power industry. (2023). *Sensors*. https://www.mdpi.com/1424-8220/23/13/5970

A comprehensive review of conventional and intelligence-based approaches for the fault diagnosis and condition monitoring of induction motors. (2022). *Energies*. https://doi.org/10.3390/en15238938

Review of fault detection and diagnosis techniques for AC motor drives. (2023). *Energies*. https://www.mdpi.com/1996-1073/16/15/5602

A review of artificial intelligence applications in predicting faults in electrical machines. (2025). *Energies*. https://www.mdpi.com/1996-1073/18/7/1616

A review of artificial intelligence techniques in fault diagnosis of electric machines. (2025). *Sensors*. https://www.mdpi.com/1424-8220/25/16/5128

A review on data-driven condition monitoring of industrial equipment. (2023). *Algorithms*. https://www.mdpi.com/1999-4893/16/1/9

Lee, J., Qiu, H., Yu, G., Lin, J., & Rexnord Technical Services. (2007). *Bearing data set.* NASA Prognostics Center of Excellence Data Set Repository. https://www.nasa.gov/intelligent-systems-division/discovery-and-systems-health/pcoe/pcoe-data-set-repository/

Metrics for offline evaluation of prognostic performance. International Journal of Prognostics and Health Management. https://papers.phmsociety.org/index.php/ijphm/article/view/1336

A survey on data mining for data-driven industrial assets maintenance. (2025). *Technologies*. https://www.mdpi.com/2227-7080/13/2/67